

# FIRE SUPPRESSION RATING SCHEDULE

**TABLE 512A PUMPER EQUIPMENT AND HOSE**

Equipment and Hose	Needed for Max Credit	
Booster tank	300 gal. or larger	
Hose:		Additional Max Hose Credited:
15' soft-suction or 20' hard-suction hose 1½", 1¾", or 2" hose carried	1 400'	200 feet of 2 inch or 2-1/2 inch attack line.
Master stream appliance (1,000 gpm)	1	
Nozzles:		1,000 feet of supply line in accordance with the general criteria NFPA 1901.
2½" playpipe with shutoff and 1", 1⅛", and 1¼" tips	1	
2½" combination spray with shutoff	1	
1½" or 1¾" combination spray with shutoff	2	
SCBA (30-minute minimum)	4	This is in addition to the 400' of 1-1/2" - 2" hose listed to the left.
Extra cylinders (carried)	4	
Salvage covers (minimum size of 12' x 14')	2	
Electric handlights	2	
Hose clamp	1	
Hydrant hose gate (2½")	1	
Gated wye (2½" x 1½" x 1½")	1	
Radio:		
Mounted	1	
Portable	1	
Ladders:		
12' to 16' roof	1	
24' extension or larger	1	
Annual tests:		
Pumper (see Table 512B)	1	
Hose (see Table 512C)	1	

**TABLE 512B PUMPER SERVICE TEST PROGRAM**

Average Interval between 3 Most Recent Tests	Maximum Points Credit
1 year	100
2 years	75
3 years	50
4 years	25
5 years or more	0

The Pumper Service Test Program shall be in accordance with the general criteria of NFPA Standard 1911, *Standard for the Inspection, Maintenance, Testing, and Retirement of In-Service Automotive Fire Apparatus*.

# FIRE SUPPRESSION RATING SCHEDULE

---

**TABLE 512C HOSE SERVICE TEST PROGRAM**

Average Interval between 3 Most Recent Tests	Maximum Points Credit
1 year	50
2 years	37
3 years	25
4 years	12
5 years or more	0

The Hose Service Test Program shall be in accordance with the general criteria of NFPA 1962, *Standard for the Inspection, Care, and Use of Fire Hose, Couplings, and Nozzles and the Service Testing of Fire Hose*.

When the hose test frequency varies, proportion the credit based upon the percent of all hose tested for each frequency.

Note: If partial records of tests exist, reduce the credit for testing by 25% for Tables 512B and/or 512C; if no records of tests exist, reduce the credit by 100% for Tables 512B and/or 512C as applicable.