

# FIRE SUPPRESSION RATING SCHEDULE

---

## Appendix B

**TABLE 542A EQUIPMENT FOR A SERVICE COMPANY**

<b>Equipment</b>	<b>Needed for Max Credit</b>
SCBA (30-minute minimum)	4
Extra cylinders (carried)	4
Salvage covers (minimum size of 12' x 14')	6
Electric generator (3,000 watt)	1
Portable floodlight (500 watt)	3
Smoke ejector (5,000 cfm)	1
Portable thermal cutting unit	1
Saw – power (chain or heavy-duty rotary type)	1
Electric handlights	4
Pike pole (plaster hook):	
3' or 4'	2
6' or longer	4
Radio:	
Mounted	1
Portable	1
Ladder:	
24' extension or longer	1
16' roof or longer	1
10' attic or longer	1
14' combination or longer	1

---